
Uninterruptible **Power for Drives**

Undervoltage Solutions



Battery Systems



B()NITRON

Long-Term Outage Protection

Bonitron Battery UPD Systems (Uninterruptible Power for Drives) are the cost effective way to ensure your critical process never sees power disturbances from voltage sags or outages lasting up to 4 minutes. Battery UPD Systems include a voltage regulator that monitors the drive's DC bus voltage. If drive voltage sags or disappears, the system becomes active immediately and provides power to the DC bus so that the process is not affected.

Product Highlights

Battery energy storage

• Full-load power for up to 4-minutes for 100%, 3-phase outages

Sized to drive system process

- Typically much lower cost than plant-wide UPS
- Support single or multiple drives with one UPD System

Parallel Connection

- High reliability
- Test system with no effect on process
- Very low standby power

Seamless power transfer from utility, to Bonitron, to generator or restored utility

• 208 – 480VAC systems



	Maximum Current	Outage Duration	Cabinet	Voltage Regulator	Charger	Energy* Storage	Interactive Display
S3534BR SERIES	40A	Up to 60 sec.	•	•	•	Battery	•
S3460BR SERIES	610A	Up to 4 min.	•	•	•	Battery	•

615-244-2825


*Supplied or acquired locally






The Bonitron UPD Advantage

Electricity travels miles to reach the drives and motors that control your process. While outdoor power lines and substations are vulnerable to power outages caused by cars, weather, and even animals, the lines inside your plant are susceptible to power quality events as well.



Unlike typical plant wide solutions, Bonitron designed its UPD solutions to connect directly to the DC terminals of one or multiple drives. If drive voltage sags, the Bonitron UPD immediately provides power so motor speed is not affected and the process never sees a disturbance. When properly sized, Bonitron UPD systems provide drives with full-load power until the AC line is restored or generators are online.


Bonitron Battery UPD Systems use battery DC energy to power the DC bus of the drive via DC bus connection terminals on the drive. This eliminates an unnecessary and energy-wasting DC to AC conversion.



Competitors' double conversion UPS systems convert DC voltage that is stored in batteries or capacitors back to AC voltage in order to power the drive, which in turn converts it back to DC. Variable frequency drives are not recommended for use with UPS Systems, as the drive input reactance interacts negatively with UPS inverters.



- Series ConnectionDecreased reliability
- Decreased efficiency
 - Unnecessary conversions
 - Converts energy storage back to AC



131010_20140425